

Supplier Declaration of Conformity

Issuer(s) details:

Legrand New Zealand Ltd
 106-124 Target Road, Glenfield Auckland, NZ
 New Zealand Company Number: 58768

Legrand Australia Pty Ltd
 Unit 4, 43-47 Lyn Parade, Prestons, NSW, 2170, Australia
 ABN: 31 000 102 661
 ACMA Supplier Code Number: N819
 EESS Supplier Code: E3

Product details:

Brand:	Legrand	
Catalogue Number(s):	659066LI 659067LI 659068LI 659069LI 659073LI 659072LI 659073LI	
Product Description:	WP2L6 LED 4K MTD LI GAL WP2L6 LED 4K MWDIM LI GAL WP2L12 LED 4K MTD LI GAL WP2L12 LED 4K MWDIM MTD LI GAL WP2 LED BATTEN 1200MM IP65 MWAVE ON/OFF MAINTAINED LI GAL WP2 LED BATTEN 600MM IP65 MWAVE ON/OFF MAINTAINED LI GALAXY WP2 LED BATTEN 1200MM IP65 MWAVE ON/OFF MAINTAINED LI GALAXY	
Supplier/Issuer Identification (as affixed on the article)		
Regulatory Compliance Mark (RCM):		Products are marked with RCM

Standards:

A sample of the product(s) listed above has been examined and found to comply with the relevant requirements of the standards listed below. Options and variants of the base models covered by this declaration, if not referred to above, are listed in the product price list/catalogue.

Standard/Regulation Number	Title
AS/NZS 60598.2.22	Luminaires - Part 2.22: Particular requirements- Luminaires for emergency lighting (IEC 60598-2-22, Ed. 3.1 (2002) MOD)
AS/NZS CISPR 15	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2000, MOD)
AS/NZS 2293.3	Emergency evacuation lighting for buildings Part 3: Emergency luminaires and exit signs
AS 60529	Degrees of protection provided by enclosures (IP Code)

Supportive documents relevant for compliance:

Title	Description
180154	Test Report
PT202, PT194, PT198, PT199	Test Reports

Authorisation:

Signature:

Signed for and on behalf of Legrand New Zealand Ltd. and Legrand Australia Pty Ltd

Name & position, as authorised by the issuer:	Dennis Galvin, Technical Director
Date of Issue:	1 November 2018