



Supplier Declaration of Conformity

Issuer(s) details:

Legrand New Zealand Ltd
 106-124 Target Road, Glenfield Auckland, NZ
 New Zealand Company Number: 58768

Legrand Australia Pty Ltd
 Unit 4, 43-47 Lyn Parade, Prestons, NSW, 2170, Australia
 ABN: 31 000 102 661
 ACMA Supplier Code Number: N819
 EESS Supplier Code: E3

Product details:

Brand:	Legrand	
Catalogue Number(s):	659000LI 659001LI 659002LI	
Product Description:	G2 LED EXIT SLIDE CONNECT WHITE RM LI GALAXY CELS G2 LED EXIT SLIDE CONNECT BLACK RM LI GALAXY CELS G2 LED EXIT SLIDE CONNECT SILVER RM LI GALAXY CELS	
Supplier/Issuer Identification (as affixed on the article)		
Regulatory Compliance Mark: RCM & R-NZ(also for radio product in NZ)	 R-NZ	
If Radio Product:	Frequency or frequency range (MHz): 915 - 928MHz	Radiated power e.i.r.p (dBW): < 126 mW (21.0 dBm)
Safety Assessment Level:	1	

Standards:

A sample of the product(s) listed above has been examined and found to comply with the relevant requirements of the standards listed below. Options and variants of the base models covered by this declaration, if not referred to above, are listed in the product price list/catalogue.

Standard/Regulation Number	Title
AS/NZS 60598.2.22	Luminaires – Part 2.22: Particular requirements- Luminaires for emergency lighting
AS/NZS CISPR 15	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment
AS/NZS 2293.3	Emergency evacuation lighting for buildings Part 3: Emergency luminaires and exit signs
AS/NZS 4268	Radio equipment and systems – Short range devices – Limits and methods of measurement

Supportive documents relevant for compliance:

Title	Description
180202	Test Report
180224	Test Report
180222	Test Report
180154	Test Report

Authorisation:

Signature:

Signed for and on behalf of Legrand New Zealand Ltd. and Legrand Australia Pty Ltd

Name & position, as authorised by the issuer:	Dennis Galvin, Technical Director
Date of Issue:	1 November 2018