

## Supplier Declaration of Conformity

### Issuer(s) details:

**Legrand New Zealand Ltd**  
 106-124 Target Road, Glenfield Auckland, NZ  
 New Zealand Company Number: 58768

**Legrand Australia Pty Ltd**  
 Unit 4, 43-47 Lyn Parade, Prestons, NSW, 2170, Australia  
 ABN: 31 000 102 661  
 ACMA Supplier Code Number: N819  
 EESS Supplier Code: E3

### Product details:

|   |  |                              |
|---|--|------------------------------|
| <b>Brand:</b>   | Legrand  |                              |
| <b>Catalogue Number(s):</b>                                       | 685051/LI<br>685061/LI<br>685081/LI<br>685091/LI   |                              |
| <b>Product Description:</b>                                       | WP2LED 600MM WPROOF 4K MICROWAVE SWITCHED MAINTAINED LI<br>WP2LED 600MM WPROOF 4K MWAVE SWITCHED MAINTAINED AXIOM LI<br>WP2LED 1200MM WPROOF 4K MICROWAVE SWITCHED MAINTAINED LI<br>WP2LED 1200MM WPROOF 4K MWAVE SWITCH MAINTAINED AXIOM LI |                              |
| <b>Supplier/Issuer Identification (as affixed on the article)</b> |  |                              |
| <b>Regulatory Compliance Mark (RCM):</b>                          |  | Products are marked with RCM |

### Standards:

A sample of the product(s) listed above has been examined and found to comply with the relevant requirements of the standards listed below. Options and variants of the base models covered by this declaration, if not referred to above, are listed in the product price list/catalogue.

| Standard/Regulation Number | Title   |
|----------------------------|---|
| AS/NZS 60598.2.22          | Luminaires - Part 2.22: Particular requirements- Luminaires for emergency lighting                                  |
| AS/NZS CISPR 15            | Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment |
| AS/NZS 2293.3              | Emergency evacuation lighting for buildings Part 3: Emergency luminaires and exit signs                             |

### Supportive documents relevant for compliance:

| Title               | Description         |
|---------------------|---------------------|
| 180374,19004, 19007 | Safety Test Reports |

**Authorisation:**



Signature:

Signed for and on behalf of Legrand New Zealand Ltd. and Legrand Australia Pty Ltd

|  |                                   |
|--|-----------------------------------|
| <b>Name &amp; position, as authorised by the issuer:</b> | Dennis Galvin, Technical Director |
| <b>Date of Issue:</b>                                    | 28 November 2019                  |