



Supplier Declaration of Conformity

Issuer(s) details:

Legrand New Zealand Ltd
 106-124 Target Road, Glenfield Auckland, NZ
 New Zealand Company Number: 58768

Legrand Australia Pty Ltd
 Unit 4, 43-47 Lyn Parade, Prestons, NSW, 2170, Australia
 ABN: 31 000 102 661
 ACMA Supplier Code Number: N819
 EESS Supplier Code: E3

Product details:

Brand:	Legrand	
Catalogue:	659090LI 659089LI 659088LI 659108LI 659109LI 659093LI 659092LI 659091LI 659110LI 659111LI 659112LI 659113LI 659114LI 659115LI 659116LI	
Product Description:	DYNAMEX LED SINGLE SIDED RECESS RMS LI GALAXY DYNAMEX LED SINGLE SIDED RECESS RML LI GALAXY DYNAMEX LED SINGLE SIDED RECESS RMR LI GALAXY DYNAMEX LED DOUBLE SIDED RECESS RMS LI GALAXY DYNAMEX LED DOUBLE SIDED RECESS RMLR LI GALAXY DYNAMEX LED SINGLE SIDED SURFACE RMS LI GALAXY DYNAMEX LED SINGLE SIDED SURFACE RML LI GALAXY DYNAMEX LED SINGLE SIDED SURFACE RMR LI GALAXY DYNAMEX LED DOUBLE SIDED SURFACE RMS LI GALAXY DYNAMEX LED DOUBLE SIDED SURFACE RMLR LI GALAXY DYNAMEX LED SINGLE SIDED SUSP REMOTE GEAR RMS LI GALAXY DYNAMEX LED SINGLE SIDED SUSP REMOTE GEAR RML LI GALAXY DYNAMEX LED SINGLE SIDED SUSP REMOTE GEAR RMR LI GALAXY DYNAMEX LED DOUBLE SIDED SUSP REMOTE GEAR RMS LI GALAXY DYNAMEX LED DOUBLESIDED SUSP REMOTE GEAR RMLR LI GALAXY	
Supplier/Issuer Identification (as affixed on the article)		
Regulatory Compliance Mark: RCM & R-NZ(also for radio product in NZ)		R-NZ
If Radio Product:	Frequency or frequency range (MHz): 915 - 928MHz	Radiated power e.i.r.p (dBW): < 126 mW (21.0 dBm)
Safety Assessment Level	1	

Standards:


A sample of the product(s) listed above has been examined and found to comply with the relevant requirements of the standards listed below. Options and variants of the base models covered by this declaration, if not referred to above, are listed in the product price list/catalogue.

Standard/Regulation Number	Title
AS/NZS 60598.2.22	Luminaires - Part 2.22: Particular requirements- Luminaires for emergency lighting
AS/NZS 2293.3	Emergency evacuation lighting for buildings Part 3: Emergency luminaires and exit signs (Normal Mode)
AS CISPR 15	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment
AS/NZS 4268	Radio equipment and systems - Short range devices - Limits and methods of measurement

Supportive documents relevant for compliance:

Title	Description
200051	Test Report
200053	Safety Test Report
180154	Test Report

Authorisation:

	
Signature:	
Signed for and on behalf of Legrand New Zealand Ltd. and Legrand Australia Pty Ltd	
Name & position, as authorised by the issuer:	Dennis Galvin, Technical Director
Date of Issue:	30 March 2020