

Supplier Declaration of Conformity

Issuer(s) details:

Legrand Australia Pty Ltd

Unit 4, 43-47 Lyn Parade, Prestons, NSW, 2170, Australia ABN: 31 000 102 661 ACMA Supplier Code Number: N819 EESS Supplier Code: E3

Legrand New Zealand Ltd

106-124 Target Road, Glenfield Auckland, NZ New Zealand Company Number: 58768

Product details:

Brand:	Legrand
Catalogue & Product Description(s)	659102LIECO WP BATTEN L6 GAL LI659103LIECO WP BATTEN L6 GAL SENSOR LI659104LIECO WP BATTEN L12 GAL LI659105LIECO WP BATTEN L12GAL SENSOR LI659106LIECO WP BATTEN L15 GAL LI659107LIECO WP BATTEN L15GAL SENSOR LI
Supplier/Issuer Identification (as affixed on the article)	L legrand [®]
Regulatory Compliance Mark: RCM	Ø
Safety Assessment Level	1

Standards:

A sample of the product(s) listed above has been examined and found to comply with the relevant requirements of the standards listed below. Options and variants of the base models covered by this declaration, if not referred to above, are listed in the product price list/catalogue.

Standard/Regulation Number	Title
AS/NZS 60598.2.22	Luminaires - Part 2.22: Particular requirements- Luminaires for emergency lighting
AS/NZS 2293.3	Emergency evacuation lighting for buildings Part 3: Emergency luminaires and exit signs (Normal Mode)
AS CISPR 15	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment
AS/NZS 4268	Radio equipment and systems - Short range devices - Limits and methods of measurement

Ƴ HPM

L[®] legrand[®]

Supportive documents relevant for compliance:

Title	Description
190139, 190142, 190145	2293 Test Reports
190141, 190144, 190147	EMC Test Reports
180154	4268 Test Report
210072	Safety Test Report

Authorisation:

WQL

Signature:

Signed for and on behalf of Legrand New Zealand Ltd. and Legrand Australia Pty Ltd

Name & position, as authorised by the issuer:	Dennis Galvin, Technical Director
Date of Issue:	1 March 2022