



Supplier Declaration of Conformity

Issuer(s) details:

Legrand New Zealand Ltd
 106-124 Target Road, Glenfield Auckland, NZ
 New Zealand Company Number: 58768

Legrand Australia Pty Ltd
 Unit 4, 43-47 Lyn Parade, Prestons, NSW, 2170, Australia
 ABN: 31 000 102 661
 ACMA Supplier Code Number: N819
 EESS Supplier Code: E3

Product details:

Brand:	Legrand	
Catalogue Number(s):	411121 411122 411124 411125 411126 411127 411128 411129 411131 411132 411133 411134	
Product Description:	RCBO DX3 2P 1MOD 6A 10MA P+N RCBO DX3 2P 1MOD 10A 10MA P+N RCBO DX3 2P 1MOD 16A 10MA P+N RCBO DX3 2P 1MOD 20A 10MA P+N RCBO DX3 2P 1MOD 25A 10MA P+N RCBO DX3 2P 1MOD 32A 10MA P+N RESID CURRENT W OVERLOAD CB DX3 1P+N 6A TYPEA 30MA 1M 230V RESID CURRENT W OVERLOAD CB DX3 1P+N 10A TYPEA 30MA 1M 230V RESID CURRENT W OVERLOAD CB DX3 1P+N 16A TYPEA 30MA 1M 230V RESID CURRENT W OVERLOAD CB DX3 1P+N 20A TYPEA 30MA 1M 230V RESID CURRENT W OVERLOAD CB DX3 1P+N 25A TYPEA 30MA 1M 230V RESID CURRENT W OVERLOAD CB DX3 1P+N 32A TYPEA 30MA 1M 230V	
Supplier/Issuer Identification (as affixed on the article)		
Regulatory Compliance Mark (RCM):		Products are marked with RCM
Safety Assessment Level:	3	

Standards:

A sample of the product(s) listed above has been examined and found to comply with the relevant requirements of the standards listed below. Options and variants of the base models covered by this declaration, if not referred to above, are listed in the product price list/catalogue.

Standard/Regulation Number	Title
AS/NZS 61009.1	Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)

Supportive documents relevant for compliance:

Title	Description
GMA-501349-EA	Safety Approval Certificate

Authorisation:

Signature:

Signed for and on behalf of Legrand New Zealand Ltd. and Legrand Australia Pty Ltd

Name & position, as authorised by the issuer:	Dennis Galvin, Technical Director
Date of Issue:	20 November 2019