



Supplier Declaration of Conformity

Issuer(s) details:

Legrand Australia Pty Ltd
 Unit 4, 43-47 Lyn Parade, Prestons, NSW, 2170, Australia
 ABN: 31 000 102 661
 ACMA Supplier Code Number: N819
 EESS Supplier Code: E3

Legrand New Zealand Ltd
 106-124 Target Road, Glenfield Auckland, NZ
 New Zealand Company Number: 58768

Product details:

Brand:	Legrand	
Catalogue Number(s) & Product Description:	643088 643089 643090 643091 643092	LEGRAND 240V SURFACE MOUNT RF INTERCONNECTED SMOKE ALARM LEGRAND 240V FLUSH MOUNT RF INTERCONNECTED SMOKE ALARM LEGRAND 240V SURFACE MOUNT INTERCONNECTED SMOKE ALARM LEGRAND 3V SURFACE MOUNT RF INTERCONNECTED SMOKE ALARM LEGRAND 240V FLUSH MOUNT INTERCONNECTED SMOKE ALARM
Supplier/Issuer Identification (as affixed on the article)		
Regulatory Compliance Mark: (RCM & R-NZ if applicable)	 R-NZ	
If Radio Product:	Frequency or frequency range (MHz): 433	Radiated power e.i.r.p (dBW): -26.44
Safety Assessment Level:	1	

Standards:

A sample of the product(s) listed above has been examined and found to comply with the relevant requirements of the standards listed below. Options and variants of the base models covered by this declaration, if not referred to above, are listed in the product price list/catalogue.

Standard/Regulation Number	Title
AS 3786	Smoke alarms using scattered light, transmitted light or ionization
ActivFire	ActivFire conformity and registration

Supportive documents relevant for compliance:

Title	Description
XF3461 (R1, R2, R3)	AS 3786 test reports
afp3743, afp3744, afp3745	ActivFire certificates of conformity
E2204-1531	EMC test report

Authorisation:



Signature:

Signed for and on behalf of Legrand New Zealand Ltd. and Legrand Australia Pty Ltd

Name & position, as authorised by the issuer:

Dennis Galvin, Technical Director

Date of Issue:

27 June 2023