

LICENCE

No. 11476 - Issue No 2

Issued to:

Applicant:

Legrand N.V.

Kouterveldstraat 9, Ind. Zone

1831 DIEGEM

Belgium

Licensee:

Legrand N.V.

Kouterveldstraat 9, Ind. Zone

1831 DIEGEM

Belgium

Product : bus bar boxes
Trade name(s) : LEGRAND
Type(s)/model(s) : 01308, 01311, 01312, 01313, 01314

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location according to CCA Group Operational Document CIG 021
- a certification agreement with the number 178

SGS CEBEC hereby grants the right to use the CEBEC certification mark



The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 02/09/2008


Mr. R. Maquestiau,
Managing Director

© Only integral publication of this certificate, including the annex, is allowed

SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	:	bus bar boxes
Trade name(s)	:	LEGRAND
Type(s)/Model(s)	:	01308, 01311, 01312, 01313, 01314
rated operational voltage (Ue)	:	400 V
rated current (In)	:	63 A
nature of supply	:	AC
rated frequency	:	50 Hz
class	:	class II
degree of protection	:	IP (with door) : IP 40
resistance to impact (IK)	:	IK : IK05

Product data - type 01308

number of modules	:	1 x 8 mod.
dimensions (HxWxD)	:	180 x 190 x 83 mm
additional information	:	IP (without door) : 01308 => IP30 IP (with door) : 01308 + 01328/01338 => IP40

Product data - type 01311

number of modules	:	1 x 13 mod.
dimensions (HxWxD)	:	235 x 250 x 99 mm
additional information	:	IP (without door) : 01311 => IP30 IP (with door) : 01311 + 01331/01341 => IP40

Product data - type 01312

number of modules	:	2 x 13 mod.
dimensions (HxWxD)	:	360 x 250 x 99 mm
additional information	:	IP (without door) : 01312 => IP30 IP (with door) : 01312 + 01332/01342 => IP40

Product data - type 01313

number of modules : 3 x 13 mod.
dimensions (HxWxD) : 485 x 250 x 99 mm
additional information : IP (without door) : 01313 => IP30
IP (with door) : 01313 + 01333/01343 => IP40

Product data - type 01314

number of modules : 4 x 13 mod.
dimensions (HxWxD) : 610 x 250 x 99 mm
additional information : IP (without door) : 01314 => IP30
IP (with door) : 01314 + 01334/01344 => IP40

TESTS

Test requirements

NBN EN 60439-3 based on EN 60439-3:1991 + A1:1994

Test results


The test results are laid down in certification file ref. 573391/01
Essais de tenue au couple de vissage : SPEC125.1-Q00269.2.1-1.doc


Remarks


This certificate is based on test report(s) ref. H68-99

Conclusion

The examination proved that all test requirements were met.

Checked by, project leader : Zanutto Luigi 2008-09-09 

Department Manager, : 
Product Certification

Certification Manager :  2008-09-09

FACTORY LOCATION(S)

Legrand Polska SP. Z O.O.
ul. Warynskiego 20
57200 ZABKOWICE SLASKIE
Poland
Manufactured type(s) : 01308

Legrand SNC
128, av. du Maréchal-de-Lattre
de-Tassigny
87045 LIMOGES CEDEX
France
Manufactured type(s) : 01308, 01311, 01312, 01313, 01314