



Certificate of Approval

ISSUED PURSUANT TO THE ELECTRICITY (CONSUMER SAFETY) ACT 2004

ISSUED TO: LEGRAND AUSTRALIA PTY LTD

CLASS OF ARTICLE: Residual Current Device

DESCRIPTION OF ARTICLE:

Residual Current Device

[1P+N, Types 'A' and 'AC', functionally independent, DIN-Rail mounting residual current operated circuit breakers with integral overcurrent protection (RCBO's)]

Rated Voltage: 230V, ac

Rated Currents: 3A, 4A, 6A, 10A, 13A, 16A, 20A, 25A, 32A, 40A.

Instantaneous Tripping Characteristic: Curve C

Rated Residual Operating Current (I delta n): 30mA

Rated Short-Circuit Capacity (Icn): 6000A

Rated Residual Making and Breaking Capacity (I delta m): 3000A

Trade Name or Mark: 'Legrand'

Volts: -

Amperes: -

Watts: -

Hertz: -

Other Name Plate Particulars:

EXAMINED FOR COMPLIANCE WITH: AS/NZS 61009.1 : 2011

TYPE REFERENCE CODE: DX3 Series (RCBO)


APPROVAL MARK:

Each electrical article of the type described above shall be marked with Approval Number NSW25992;

or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

DATE OF APPROVAL: 17/08/2012

This approval expires 17/08/2017 unless suspended, cancelled, renewed or extended.



21-8-2012

For Commissioner for Fair Trading



Fair
Trading

Ref: NSW25992/1

ADDENDUM TO CERTIFICATE OF APPROVAL NSW25992

Particulars of Modification(s)

The addition of the following Models:-

- (a) Type AC, 300mA.
Rated Currents: 3A, 4A, 6A, 10A, 13A, 16A, 20A, 25A, 32A, 40A.
- (b) Types A and AC, 10mA
Rated Current: 16A
- (c) Type A, 300mA
Rated Currents: 10A, 16A, 20A, 40A

This Certificate of Approval expires 17 August 2017.

Approved: 17 August 2012

A handwritten signature in black ink, followed by the date "21.8.2012" written in a similar style.

For Commissioner for Fair Trading